

# DECLARATION OF CONFORMITY

Hereby :

**Société TRIONYX s.a.s.**  
**138, avenue Henri BARBUSSE**  
**92140 CLAMART (France)**

Certify :

**Safety cabinet – Série 7.90+**

Reference :

**791+E – 792+E – 793+E – 794+E (BVK1) – 795+E (BVK2) – 798+E**  
**795-900+E**

Are tested and homologated 90 minutes according to the standard EN 14470-1 :2004 and to **FM 6050** (Factory Mutual).

These products have a **fire resistance of 105 minutes**.

Standardized labels are in accordance with **ISO 3864, ISO 7010, 92/58/CEE European Directive** and **EN 14470-1**.

Moreover, the manufacture quality is controlled before expedition according to **ISO 9001** process and procedure.

To whom it may concern.

Clamart, the 10<sup>th</sup> of September 2019

  
Jean Philippe THIEULIN  
Directeur Général

  
Cendrine SERRE-DARGNAT  
Responsable Qualité